

# Levelton Consultants Ltd.

Fraser Valley Group and Southern Interior



#110, 34077 Gladys Avenue  
Abbotsford, BC V2S 2E8  
Tel: (604) 855-0206  
Fax: (604) 853-1186  
Email: abbotsford@levelton.com

#301, 19292-60 Avenue  
Surrey, BC V3S 3M2  
Tel: (604) 533-2992  
Fax: (604) 533-0768  
Email: surrey@levelton.com

#108, 3677 Hwy 97N  
Kelowna, BC V1X 5C3  
Tel: (250) 491-9778  
Fax: (250) 491-9729  
Email: kelowna@levelton.com

**Client:** AT & H Industries Inc.  
**Project:** Materials Testing  
**Site Address:** N/A

**File No.:** FV12-1896-00  
**Task:**

## Report of Grain Size Analysis

**Sample Location:** N/A

**Supplier:** AT & H Industries Inc.

**Material Type:** Agg Sand

**Usage:** N/A

**Specification:** N/A

**Sampled By:** Client

**Tested By:** ARP

**Date Sampled:** 1-Nov-12


**Date Tested:** 2-Nov-12

**Sieve No. 9**

**Moisture Content (as received):** 5%

**Washed Sieve**

Screen Opening (mm):	% Passing Total:	Specification	
		Upper Limit	Lower Limit
150.0			
100.0			
75.0			
50.0			
37.5			
25.0			
19.0			
12.5			
9.51			
4.75	100.0%		
2.36	99.6%		
1.18	98.2%		
0.600	88.5%		
0.425			
0.300	9.2%		
0.150	0.9%		
0.075	0.0%		



Remarks: \_\_\_\_\_

**Levelton Consultants Ltd.**

Reporting of these results constitutes a testing service only.

No engineering interpretation of the results is expressed or implied.

Engineering review and interpretation of these results can be provided upon written request.

Per: \_\_\_\_\_

Anton Parsons, ASCT