



VALLEY TESTING SERVICES LTD.

#18 - 3275 McCallum Road ph: 1-888-855-9733
 Abbotsford, B.C. V2S 7W8 fax: (604) 855-7378

**SIEVE ANALYSIS REPORT
 8 16 30 50 SERIES**

PROJECT NO. V6044

CLIENT AT& H INDUSTRIES INC.
 C.C.

TO
 AT& H INDUSTRIES INC.
 P. O. BOX 38, STN. WHONNOCK
 MAPLE RIDGE,, BC


ATTN: HOLLY LONG

PROJECT FINE AGGREGATES
 SIEVE ANALYSIS
 CONTRACTOR

MAPLE RIDGE

SIEVE TEST NO. 1 DATE RECEIVED 2012.Dec.19 DATE TESTED 2012.Dec.19 DATE SAMPLED 2012.Dec.19

SUPPLIER	AT & H INDUSTRIES	SAMPLED BY	CLIENT
SOURCE	25450 LOUGHEED HWY	TESTED BY	EB
SPECIFICATION		TEST METHOD	DRY
MATERIAL TYPE	BLEND/CLINKER SAND		



GRAVEL SIZES	PERCENT PASSING	GRADATION LIMITS
3"	75 mm	
2"	50 mm	
1 1/2"	37.5 mm	
1"	25 mm	
3/4"	19 mm	
1/2"	12.5 mm	
3/8"	9.5 mm	

SAND SIZES AND FINES	PERCENT PASSING	GRADATION LIMITS
No. 4	4.75 mm	100.0
No. 8	2.36 mm	99.7
No. 16	1.18 mm	98.0
No. 30	600 µm	87.9
No. 50	300 µm	11.1
No. 100	150 µm	1.3
No. 200	75 µm	0.3

COMMENTS